

# Energy Efficiency Analysis: Portland State University - East Hall

TEAM #2 Mitsutaka Shirasaki Chih-jen Yu Yongjun Lee Pallavi Sandanshiv Qin Guo

ETM 535/635 - ADVANCED ENGINEERING ECONOMICS

Professor: William Eisenhauer

Spring 2015

Portland State University

# **Table of Contents**

| TABLE OF CONTENTS                                     |
|---|
| LIST OF FIGURES4                                      |
| LIST OF TABLES5                                       |
| ABSTRACT  |
| INTRODUCTION  |
| Background  |
| East Hall Building Description10                      |
| HISTORICAL EAST HALL BUILDING ENERGY USE              |
| SUMMARY OF PROPOSED ENERGY EFFICIENCY MEASURES        |
| METHODOLOGY12   |
| Optional/Alternatives Analysis                        |
| Sensitivity Analysis                                  |
| ASSUMPTIONS   |
| GENERAL COMMON ASSUMPTIONS                            |
| LIGHTING  |
| Refrigerator14  |
| Air-conditioning14                                    |
| ANALYSIS OF THE PROPOSED ENERGY EFFICIENCY MEASURES14 |
| LIGHTING: OCCUPANCY/VACANCY SENSORS14                 |
| Refrigerator20  |
| Air-conditioning                                      |
| RESULTS   |
| LIGHTING: OCCUPANCY/VACANCY SENSOR                    |
| Refrigerator  |
| Air-conditioning                                      |
| CONCLUSION AND RECOMMENDATIONS                        |
| REFERENCES  |

| APPENDIX   | 34 |
|------------|----|
| Appendix A | 34 |
| Appendix B | 41 |
| Appendix C | 42 |

# **LIST OF FIGURES**

| Figure 1: Distribution of LEED Award                                  | 7  |
|---|----|
| Figure 2: LEED certificates (source: www.usgbs.org)                   |    |
| Figure 3: Sensitivity Analysis - Lighting - Energy Efficiency Measure | 20 |
| Figure 4: AC Option 1 Sensitivity Analysis                            | 28 |
| Figure 5: AC option 2 Sensitivity Analysis                            | 29 |
| Figure 6: AC Option 3 Sensitivity Analysis                            | 29 |

# **LIST OF TABLES**

| Table 1: LEED Certified Buildings in PSU                           | 8  |
|--|----|
| Table 2: East Hall Floor Data                                      | 10 |
| Table 3: East Hall Electricity - Natural Gas Usage Historical Data | 11 |
| Table 4: Option Analysis - Occupancy/Vacancy Sensors               | 16 |
| Table 5: Options Summary: Investment Cost and No. of Sensors       | 19 |
| Table 6: Annual Electricity Cost of Old Refrigerators              | 21 |
| Table 7: Annual Electricity Cost of New Refrigerators              | 22 |
| Table 8: Requirement analysis for AC in 2nd and 3rd floor          | 23 |
| Table 9: AC option 1 analysis                                      | 24 |
| Table 10: AC Option 2 analysis                                     | 25 |
| Table 11: AC Option 3 Analysis                                     | 26 |
| Table 12: AC cost saving analysis for proposed options             | 27 |
| Table 13: Summary of AC analysis on East Hall                      | 31 |
|  |    |

### ABSTRACT

With the increased awareness of the environmental sustainability, Energy Efficiency has been regarded as one of the key factors with respect to the greenness of buildings. PSU has committed to contribute this by joining American College and University Presidents' Climate Commitment community and strive to search for green building or LEEDS certification. However, the old buildings in PSU seems not been received relative attention on improving energy consumption. This led to this project objective of investigating the East Hall, one of the oldest building in PSU on the aspects of energy efficiency and saving.

By conducting site survey, collecting market information, and reviewing relevant literature, three Energy Efficiency Measures including Install Occupancy/Vacancy Sensors, Replace mini Refrigerators, and Improve AC system have been identified. For each measure, several options were proposed and analyzed by using Engineering Economics methods such as Present Worth (PW), Annual Worth (AW), and Sensitivity Analysis, in order to investigate the cost and benefit/saving in more detail.

The analysis of each Energy efficacy Measure are coupled with sensitivity analysis, which identify the key variables influencing the research results and can be served as an aid for utility management decision.

# Introduction

Portland State University (PSU) is one of over 600 signatories to the American College and University Presidents' Climate Commitment (ACUPCC). This commitment challenges universities to take a critical role in imposing restraints on greenhouse gas emissions. PSU joined the ACUPCC on May 24th, 2010, and aims at achieving "carbon neutrally" by 2040 [1]. To accomplish this, PSU has developed the Climate Action Plan Implementation Team (CAP-IT) to construct greener buildings or LEED certificated buildings.

LEED, or leadership in Energy and Environmental Design, introduced by the Green Building Certification Institute (GBCI) in 1998, is a green building certification program that recognizes best - in -class building strategies and practices [2]. Before a building can be certificated, it must be evaluated according to the criteria shown in the Figure-1 below. Altogether a total of 100 points could be achieved in the standard categories. Despite the standard points, which are awarded for all types of buildings, it is probable to gain up to ten bonus points for particularly innovation ideas [3]. The following diagram illustrates the different categories for which the 100 standard points are awarded.



#### **Figure 1: Distribution of LEED Award**

Final evaluation is divided into four different rankings:

- LEED platinum: more than 80 points
- LEED Gold: 60~79 points
- LEED Silver: 50~59 points
- LEED certificated: 40~49 points



Figure 2: LEED certificates (source: www.usgbs.org)

Since PSU joined the ACUPCC, nine buildings have been certificated different LEED Certification Level, which is shown in the Table 1.

| Building                             | LEED Certification Level | Construction    |
|--------------------------------------|--------------------------|-----------------|
| Academic & Student Recreation Center | GOLD                     | 2009            |
| Biology Research Greenhouse          | SILVER                   | 2008            |
| Broadway                             | SILVER                   | 2004            |
| Collaborative Life Sciences Building | PLATINUM                 | 2014            |
| Engineering Building                 | GOLD                     | 2004            |
| Lincoln Hall                         | PLATINUM                 | 2011 Renovation |
| Science Research & Teaching Center   | GOLD                     | 2011 Renovation |
| Shattuck Hall                        | GOLD                     | 2010 Renovation |
| Stephen Epler Residence Hall         | SILVER                   | 2003            |

Table 1: LEED Certified Buildings in PSU

### Background

The Portland State University (PSU) East Hall building is one of the oldest facilities built in 1924. East Hall is a Georgian Courtyard style three-story U-shaped brick and timber building located on the corner of SW Hall Street and Broadway, Portland Oregon. It was originally an apartment building acquired by Portland State University in 1966, and since then, it functions as an administrative and academic space for diverse programs such as [4]:

- Center for Japanese Studies
- Institute for Asian Studies
- International Special Programs
- International Studies Program
- Middle Eastern Studies Center
- Office of International Affairs
- Waseda Transnational Program

#### Building Naming History [4]:

- East Hall (EH) 1999-present
- College of Urban and Public Affairs (CUPA) -1998-1999
- School of Urban and Public Affairs (UPA) 1988-1997
- East Hall (EH) 1966-1987
- Nixon Apartments -1924-1966

# **East Hall Building Description**

Location: Portland, Oregon

Year Built: 1924

Floor Area: 23,390 square foot (Gross floor area)

**Type of facility:** Mix of offices, classrooms and student lounges.

**Operating hours:** Monday – Friday (9:00 am – 5:00 pm), Closed on Weekends (Saturday – Sunday).

Number of Floors: 3

|                         | First Floor       | Second Floor      | Third Floor       |
|-------------------------|-------------------|-------------------|-------------------|
| Number of Room          | 23                | 33                | 35                |
| Total Floor Size (room) | 4,703 square foot | 5,194 square foot | 6,103 square foot |

Table 2: East Hall Floor Data

# Historical East Hall building energy use

The Table 3 below presents utility usage historical data for a two-year period 2013-2014. This includes all three floors of the main building - electric and gas meters.

| Month    | Electric<br>Use (KWh) | Electric Use<br>(KWh) | Electric Use<br>(KWh) | Natural Gas<br>Usage<br>(Therms) | Natural Gas<br>Usage<br>(Therms) | Natural Gas<br>Usage<br>(Therms) |
|----------|-----------------------|-----------------------|-----------------------|----------------------------------|----------------------------------|----------------------------------|
|          | 2014                  | 2013                  | Average               | 2014                             | 2013                             | Average                          |
| January  | 7,965                 | 8,737                 | 8,351                 | 1,504                            | 1,574                            | 1,539                            |
| February | 8,324                 | 8,469                 | 8,397                 | 1,514                            | 1,378                            | 1,446                            |
| March    | 7,511                 | 8,243                 | 7,877                 | 1,307                            | 1,023                            | 1,165                            |

| Month                           | Electric<br>Use (KWh) | Electric Use<br>(KWh) | Electric Use<br>(KWh) | Natural Gas<br>Usage<br>(Therms) | Natural Gas<br>Usage<br>(Therms) | Natural Gas<br>Usage<br>(Therms) |
|---------------------------------|-----------------------|-----------------------|-----------------------|----------------------------------|----------------------------------|----------------------------------|
| April                           | 7,611                 | 8,356                 | 7,984                 | 171                              | 908                              | 540                              |
| May                             | 7,681                 | 8,003                 | 7,842                 | 537                              | 524                              | 531                              |
| June                            | 6,998                 | 8,001                 | 7,500                 | 338                              | 210                              | 274                              |
| July                            | 7,569                 | 7,551                 | 7,560                 | 114                              | 109                              | 112                              |
| August                          | 8,661                 | 8,129                 | 8,395                 | 98                               | 107                              | 103                              |
| September                       | 8,613                 | 7,259                 | 7,936                 | 121                              | 498                              | 310                              |
| October                         | 8,748                 | 7,550                 | 8,149                 | 670                              | 849                              | 760                              |
| November                        | 9,315                 | 8,642                 | 8,979                 | 1,304                            | 1,351                            | 1,328                            |
| December                        | 7,448                 | 7,787                 | 7,618                 | 1,522                            | 1,940                            | 1,731                            |
| Total                           | 96,444                | 96,727                | 96,586                | 9,200                            | 10,471                           | 9,836                            |
| Cost (\$)                       | \$5,557.11            | \$5,377.75            | \$5,467.43            | \$9.723.61                       | \$9,703.88                       | \$9,713.74                       |
| Total Energy Use in kBtu        |                       |                       |                       | 1,313,292.897                    |                                  |                                  |
| Total Gross SqFt                |                       |                       |                       | 23,390                           |                                  |                                  |
| Energy Use Index kBtu/sqft/year |                       |                       |                       | 56.15                            |                                  |                                  |

Table 3: East Hall Electricity - Natural Gas Usage Historical Data

For the purpose of this project analysis, energy efficiency options are suggested for East Hall's electricity usage only and natural gas energy efficiency alternatives are not suggested or evaluated.

### **Summary of Proposed Energy Efficiency Measures**

**Energy Efficiency Measure 1**: Install Occupancy/Vacancy Sensors to control HVAC system in Hallways and Stairways on each floor of East Hall.

**Energy Efficiency Measure 2**: Replace small old refrigerators on each floor to new high capacity common refrigerators.

Energy Efficiency Measure 3: Improve the Air-conditioning measures (AC's) on each floor.

# Methodology

### **Optional/Alternatives Analysis**

In practice, there are usually a limited number of feasible alternatives to evaluate for an engineering project. When two or more mutually exclusive alternatives are evaluated, the decision is made easier if following steps are considered:

The alternative that requires the minimum investment of capital and produces satisfactory functional results will be chosen unless the incremental capital associated with an alternative having a larger investment can be justified with respect to its incremental benefits. Namely, if the extra benefits obtained by investing additional capital are better than those that could be obtained from investment of the same capital elsewhere in the company at the MARR, the investment should be made [5].

In optional analysis, there are few key important points. First, the selected study period must be adequate for the decision situation under investigation. So the comparison should be implemented in same equivalent condition. Second, the IRR of mutually exclusive alternatives are not compared against those of other alternatives. Just compare an IRR only against MARR. Thus, the alternative associated with the extra investment should be selected if the rate of return available through the incremental cash flow equals or exceeds the MARR.

# **Sensitivity Analysis**

The traditional means to evaluate risk is through sensitivity. In a normal sensitivity analysis, the value of an input variable identified as a significant potential source of uncertainty is changed while all other input values are constants, and the amount of change in analysis results is indicated. This sensitivity process is repeated for other input variables for risk analysis. The input variables may be ranked according to the effect of their variability based on analysis.

Sensitivity analysis provides the impact of the variability of individual inputs on overall economic results. In general, if sensitivity analysis reveals that reasonable changes in an uncertain input variable will not change the relative economic ranking of project alternatives or undermine the project's economic justification, then the analyst can have reasonable comfort from the results. Alternatively, a reasonable change in an uncertain input value could severely diminish the project's economic justification. If so, the analyst would investigate method to reduce the risk of a change and minimize consequences when the adverse event occurs. If the risk cannot be mitigated, the analyst may recommend another project design [6].

Sensitivity Analysis methods can be classified in a variety of ways. They are classified as mathematical, statistical and graphical. In this report, mainly mathematical and graphical methods were applied for sensitivity analysis of the alternatives [7].

# Assumptions

# **General Common Assumptions**

- 1. The average electricity cost considered is \$0.06 per kWh, based on the information or data provided by Facilities department at Portland State University.
- 2. MARR 11%: information provided by Finance department at PSU.
- 3. For calculation purpose of all three energy efficiency measures, useful life is considered 7 years.

# Lighting

 For the other office space lights – such as offices, classrooms, and conference rooms – it is assumed that the staff will turn the lights off when they leave after working hours on weekdays.

- 2. It is assumed that facilities department at Portland State University will be able to install the occupancy sensors at East Hall and cost of installation is not considered in the initial investment of each option.
- 3. The electricity cost of operating occupancy/vacancy sensors is negligible due to very low wattage value, therefore it is not considered in operation/maintenance cost of evaluating each lighting alternative.

### Refrigerator

- 1. According to the site survey, the old mini refrigerators in East Hall are all of different brands and no information of the brand or model is available, therefore it is more difficult to calculate the electricity cost of each one. So assumption is made that all the mini refrigerators have the same wattage- 0.45 kWh since the capacity of each mini refrigerator is nearly same.
- 2. Through the online literature review of the average usage of old mini refrigerators, it was found that the average working hours are around 10 hours per day. While for new energy-efficient full-sized refrigerators, the mean working hours are assumed as 6 hours per day.

# **Air-conditioning**

- 1. For calculating the AC working period, it is assumed that the AC will turn on 10 hours a day from 8:00 am to 6:00 pm. In views of the temperature change in different seasons, it is assumed that AC will need to operate from May to October, which is equivalent to 6 months or 132 working days.
- 2. According to the MACRS table, the AC may be considered in the "office furniture and equipment class" [5]. Therefore, it is assumed that the GDS (Recovery period) is 7 years. The SV in the end of the 7 years will be assumed to be zero.

# **Analysis of the Proposed Energy Efficiency Measures**

# **Lighting: Occupancy/Vacancy Sensors**

Based on the observations and survey information, lights in the hallways and stairways of East Hall are 'ON" 24/7 including the closed business hours of operation from 5:00 pm to 8:00 am on weekdays

in addition to 24 hours on weekends. Lights must be kept ON for the security reasons, but some scope of energy savings is possible if occupancy/vacancy sensors are installed only for hallways and stairway lights. This will not only serve the purpose of security but also save some electricity by turning the lights ON only when it detects any motion or activity. Appendix A: Table 1 provides information about the total number of light fixtures in hallway and stairway for all three floors (right, left and central lobby area). To check for the feasibility of investing in occupancy/vacancy sensor, it is important to know how much electricity is consumed now and how much will be saved if the occupancy/vacancy sensors are installed.

For Hallways and Stairway lights turned on 24/7:

Annual Total Energy Cost = Number of days in a year (days) \* Hours of operations (hours)\* Cost of Electricity (\$/kWh) \* Wattage value (kWh)

= 365 days \* 24hours \* \$0.06 \* 0.828kW = \$435.196 per year

In case if occupancy/vacancy sensors are installed, the lights in hallways and stairways will be ON only during the working hours of operation 8:00 am – 6:00 pm on weekdays (assuming 10 hours) and will be turned OFF during closed hours i.e. 6:00 pm – 8:00 am on weekdays and 24 hours on weekends.

Assuming that the lights in hallways/stairways are on for 10 hours during working days:

Cost of Electricity = 260days \* 10hours \* \$0.06 \* 0.828 kW = **\$129.68** per year

Therefore, Annual Savings (Hallway and Stairway lights) = \$435.196/year - \$129.68 /year

= \$ 306.028 per year

So, it is worth looking for occupancy/vacancy sensor options further as the annual savings is \$306.028 per year.

#### **OPTION ANALYSIS:**

A large variety of occupancy and vacancy sensors are available in market with variable price options, brands, technology such as passive infrared (PIR), Ultrasonic, dual technology (PIR plus Ultrasonic) depending on the method it detects activity, mounting options such as wall-switch/ ceiling mount – 360 degree or 180 degree so on.

From amongst the large available variety of sensor options, three ceiling mount occupancy/vacancy sensors were selected that are considered best for application in hallways areas with a focus on three price ranges– economical/ costly /most expensive. Ease of installation, 360-degree coverage and high linear activity detection feature are also considered for selection of occupancy/vacancy sensors suitable and matching with the space characteristics of East Hall, refer Appendix A – Table 2 for detailed space characteristics. For the purpose of this project analysis, below mentioned are the only 3 occupancy/vacancy sensors [8] [9] [10] evaluated, but there is scope for other sensor options that can also be considered.

Table 4 provides list of ceiling mount occupancy/vacancy sensors that were analyzed to control the lights on/off time in case for hallway/stairway fixtures excluding rooms/classrooms and offices.

|  | Sensor                 |
|--|------------------------|
| Alternative 1 (360-degreePassive Infrared) [8] | Lutron LRF2-OCR2B-P-WH |
|  | WT-2255                |
| Alternative 2 (360-degree Ultrasonic) [10]     | CI-305                 |
|  | CI 3051                |
|  | SLSCUS2001             |
| Alternative 3 (360-degree Ultrasonic) [9]      | SLSCUS1001             |
|  | SLSCUS501              |

Table 4: Option Analysis - Occupancy/Vacancy Sensors

#### **Option 1:**

Option 1 is the most economical alternative compared to alternative 2 and 3 with respect to price. Lutron's LRF2-OCR2B-P-WH, is a battery powered passive infrared technology occupancy/vacancy sensor capable of covering 29 linear feet hallway area when mounted at a ceiling height of 9 feet and it detects heat from people moving within an area to determine when the space is occupied. It requires CR 123 lithium battery and is designed to have 10-year battery life (For reference – see Appendix D for datasheet). The initial investment cost is \$1386.25 and total quantity of required sensors is 25 for all three floors of East Hall - hallway and stairways. The details are mentioned in summary table 5 below. The present worth of option 1 is as follows:

Present Worth = -\$1,386.25 + \$306.03 (P/A, 11%, 7) =\$ 55.81

#### **Option 2:**

Option 2 considers 3 different specification occupancy/vacancy sensors of brand Wattstopper -

- (1) Ultrasonic Sensor WT 2255 (360-degree two-sided, 90 linear feet)
- (2) PIR Sensor CI-305 (44 linear feet)
- (3) PIR Sensor CI 305 -1 (24 linear feet)

The PIR sensor are required only for Floor 1 – Hallway space: C104 (120 sqft), V101 (131 sqft) and C105 (128 sqft). The ultrasonic sensor has bigger coverage range 90 linear feet and the required coverage range for the space mentioned is less than 40 linear feet. Therefore, PIR sensors of the same company brand, suitable for smaller hallways, can cover all the 3 mentioned areas of floor 1. The wattage (voltage and current) requirement for the all three mentioned sensors is negligible and therefore it is not considered in the further calculations. The initial investment cost is \$1841.88 and total quantity of required sensors is 12 for all three floors of East Hall - hallway and stairways. The details are mentioned in summary table 5 below. The present worth of option 2 is as follows:

Present Worth = -\$1,841.88 + \$306.03 (P/A, 11%, 7) = - \$399.82

#### **Option 3:**

Option 2 considers 3 different specification occupancy/vacancy sensors of brand Schneider are is the most expensive sensors of all the three evaluated alternatives–

- (1) Ultrasonic Sensor SLSCUS2001 (360-degree two-sided, 90 linear feet)
- (2) Ultrasonic Sensor SLSCUS1001 (360-degree two-sided, 1000 sqft area)
- (3) Ultrasonic Sensor SLSCUS501 (360-degree two-sided, 500 sqft area)

Similarly as in case of option 2, the SLSCUS1001 and SLSCUS501 sensor are required only for Floor 1 – Hallway space: C104 (120 sqft), V101 (131 sqft) and C105 (128 sqft). The ultrasonic sensor-SLSUS2001 has bigger coverage range 90 linear feet and the required coverage range for the space mentioned is less than 40 linear feet. The wattage (voltage and current) requirement for the all three mentioned sensors is negligible and therefore it is not considered in the further calculations. The initial investment cost is \$2300 and total quantity of required sensors is 12 for all three floors of East Hall - hallway and stairways. The details are mentioned in summary table 5 below. The present worth of option 3 is as follows:

Present Worth = -\$2,300 + \$306.03 (P/A, 11%, 7) = - \$857.94

For each option – Total number of sensors required and initial investment cost is summarized in below table:

|                           | Option 1               | Option 2   | Option 3     |
|---------------------------|------------------------|------------|--------------|
| Sensor 1                  | Lutron LRF2-OCR2B-P-WH | WT-2255    | SLSCUS2001   |
| Courses 2                 |                        | CL 205     | CL CCUC4 004 |
| Sensor 2                  |                        | CI-305     | SLSCUS1001   |
| Sensor 3                  |                        | CI 3051    | SLSCUS501    |
| Cost 1                    | \$55.45                | \$132.99   | \$158        |
| Cost 2                    |                        | \$87       | \$142.50     |
| Cost 3                    |                        | \$72       | \$119        |
| Floor 1 - Hallway         | \$388.15               | \$512      | \$720        |
| Left side                 | 3                      | 2,1        | 2,1          |
| Right side                | 2                      | 1          | 1            |
| Center                    | 2                      | 1          | 1            |
| Floor 2 - Hallway         | \$332.70               | \$399      | \$474        |
| Left side                 | 2                      | 1          | 1            |
| Right side                | 2                      | 1          | 1            |
| Center                    | 2                      | 1          | 1            |
| Floor 3 - Hallway         | \$332.70               | \$399      | \$474        |
| Left side                 | 2                      | 1          | 1            |
| Right side                | 2                      | 1          | 1            |
| Center                    | 2                      | 1          | 1            |
| Stairs                    | 332.7                  | 531.96     | 632          |
| Sensors- stairway         | 6                      | 4          | 4            |
| Total Cost of Alternative | \$1,386.25             | \$1,841.88 | \$2,300.00   |
| Total Sensors             | 25                     | 12         | 12           |

Table 5: Options Summary: Investment Cost and No. of Sensors

#### **Sensitivity Analysis:**

Therefore, as the present worth of option 2 and 3 is negative, option 1 is the only alternative that is further analyzed for sensitivity study and the effect of cost of electricity, MARR and capital investment change is evaluated. As can be observed from the figure below, capital investment and cost of electricity are considered more sensitive to the PW, due to steeper slope. The MARR seems less sensitive to the PW, compared with the capital investment.



Figure 3: Sensitivity Analysis - Lighting - Energy Efficiency Measure

#### Refrigerator

Previous study shows that some mini refrigerators consume as much energy as a full-sized refrigerator [11]. For example, the Magic Chef MCBR445W has a claimed capacity of 4.4 cubic feet, along with glass shelves, a can dispenser, and other useful features. It costs \$180 but could cost you \$40 per year to run if the refrigerator temperature is set to the recommended 37 degrees (based on the Oregon average of 6 cents per kilowatt hour) [12]. Refer Appendix B for detailed description.

According to the results of the site survey of East Hall, there are 16 mini and old refrigerators in the building that cost as much as \$1,576.8 annually. Since the yearly electricity bill is around \$7,000, the electricity cost of mini refrigerators is more than 20% of the total electricity usage. Refer below table for summary of old refrigerator data:

Average capacity of a mini refrigerator= 4.4 cubit feet

Average wattage for a min refrigerator= 0.45 kWh

Electricity cost in the city of Portland= \$0.06 kWh

| Floor             | Number | Total      | Wattage kWh | Annual           |
|-------------------|--------|------------|-------------|------------------|
|                   |        | capacity   |             | Electricity Cost |
|                   |        | cubit feet |             |                  |
|                   |        |            |             |                  |
| 1                 | 3      | 13.2       | 1.35        | \$295.65         |
| 2                 | 3      | 13.2       | 1.35        | \$295.65         |
| 3                 | 10     | 44         | 4.5         | \$985.50         |
| Total Annual Cost |        |            |             | \$1,576.80       |

Old Refrigerators:

#### Table 6: Annual Electricity Cost of Old Refrigerators

Therefore, as one of the measure it was determined to replace the old, mini refrigerators with energy efficient full-sized refrigerators. In order to decrease the electricity cost of refrigerators with a minimum capital investment, some survey on the new refrigerators is done, such as purchasing prices, after-sale services, and estimated annual energy cost. Among all the researched energy efficient refrigerators, it was found that FFTR1821QB and LTCS24223S are more suitable for East Hall with regard to the purchasing price and capacity.

#### New Refrigerators:

| Floor    | Number | Capacity<br>cubic feet | Model             | Purchasing<br>Price | Wattage<br>kWh | Annual<br>Electricity<br>Cost |
|----------|--------|------------------------|-------------------|---------------------|----------------|-------------------------------|
| 1        | 1      | 18                     | <u>FFTR1821QB</u> | \$497.70            | 0.404          | \$53.09                       |
| 2        | 1      | 18                     | FFTR1821QB        | \$497.70            | 0.404          | \$53.09                       |
| 3        | 2      | 47.76                  | <u>LTCS24223S</u> | \$997.20            | 1.002          | \$131.66                      |
|          |        |                        |                   | (Home Depot)        |                |                               |
| Total Co | st     |                        |                   | \$1,992.60          |                | \$237.83                      |

**Table 7: Annual Electricity Cost of New Refrigerators** 

Therefore, the annual saving of the replacing option will be

*Annual Saving* = \$1,576.8 - \$237.83 = \$1,338.97

With a capital investment \$1,992.60, it is possible to calculate the breakeven point of this investment. To find the breakeven point in years (N), the PW is set equal to zero.

PW = \$ - 1,992.6 + \$1,338.97(P/A, 11%, N) = 0

From TABLE, it can be seen that  $1 \le N \le 2$  year.

#### **Air-conditioning**

#### **AC Requirements Analysis**

After conducting the site survey, it was found that first floor had equipped with central AC system in almost every room/offices. However, there is some AC in-sufficiency found in 2<sup>nd</sup> and 3<sup>rd</sup> floor. The current 3 AC in each floor are not sufficient enough to meet East Hall second and third floor cooling requirements. Based on the Energy Star website, the 700 up to 1,000 sq. ft. will need 18,000 BTU per hour [13]. This will give us the minimum cooling capacity of 112,626 and 114,822 BTUs/hr for these two floors respectively. Therefore, the current capacity of 54,000 BTU is indeed not sufficient enough to provide a sense of comfortable work environment. The minimum total capacity needed is 108,000 BTU in 2nd and 3rd floor after calculation with estimating 95% of variance in each floor. The calculation is shown in the table below.

|   | Second floor  | Third floor   | Total              |
|---|---------------|---------------|--------------------|
| Square Footage of East Hall (sq. ft.)                 | 6,257         | 6,379         | 12,636             |
| Minimum cooling capacity required (BTU/hr)            | 112,626       | 114,822       | 227,448            |
| Current Air Conditioning (3 Air Conditioning)(BTU/hr) | 54,000        | 54,000        | 108,000            |
| The required capacity needed (95%~100%)               | 54,000~58,626 | 54,000~60,822 | Minimum<br>108,000 |
| Total minimum cooling capacity required (BTU/hr)      | 108,000       | 108,000       | 216,000            |

Table 8: Requirement analysis for AC in 2nd and 3rd floor

#### **Options Analysis**

In order to meet the gap that we observed during the site survey, there are three options proposed to both consider the energy efficiency and work environment improvement, which are listed as follows:

- 1. Option 1: Install 3 additional Air Conditioners in both second and third floor.
- Option 2: Upgrade the AC (two 36,000 BTU AC) + sell two old ACs (save the installation cost) for both second and third floor.
- 3. Option 3: Install 58 Window mounted AC (30 for second floor and 28 for third floor)

The above 3 options are proposed to operate 10 hours per day and 22 days per month in order to exactly meet the working requirement. The analysis of these 3 options is briefly described in the following sections. The detailed Excel calculation is attached in Appendix C.

#### **Option 1 Analysis**

Based on the existing AC setting in East Hall and consider the insufficiency of cooling capacity, 3 similar types of AC system with each 18,000 BTU capacity is suggested to be installed in both 2<sup>nd</sup> and

3<sup>rd</sup> floors. After collecting market information and conducting estimation of expenses, the calculation is depicted in the table 9 below.

|                            | 2 <sup>nd</sup><br>Floor | 3 <sup>rd</sup><br>Floor | Total  | Notes  |
|----------------------------|--------------------------|--------------------------|--------|--|
| Capital<br>investment      | 5,400                    | 5,400                    | 10,800 | DAIKIN equivalent split system (unit price:<br>\$1,800) with total 54,000 BTU capacity (18,000<br>BTU*3 units) for each floor. |
| Operating cost<br>per year | 332.16                   | 332.16                   | 664    | Based on \$0.06 of unit cost per kWh, 1.398 kW<br>power per unit, 10 hr. daily usage, 132 working<br>days per year.            |
| Useful life                | 7                        | 7                        |        | Based on "office furniture and equipment" asset class 00.11.   |
| MARR                       | 11%                      | 11%                      |        |  |
| Annual<br>maintenance fee  | 137                      | 137                      | 275    | [14]   |
| Installation cost          | 1,239                    | 1,239                    | 2,479  | [14]   |

 Table 9: AC option 1 analysis

PW (Option 1) = -10,800 - (664+275) (P/A, 11%, 7) - 2478.87 =\$ -17,701.56

AW (Option 1) = \$3,756.54

# **Option 2 Analysis:**

Considering the lowest impact of the current East Hall pipeline layout, option 2 contains upgrading 2 AC systems, selling the 2 old AC and making the best use of the current pipeline structure, so that the installation can be reduced to some extent. The calculation is listed below.

|                              | 2 <sup>nd</sup> Floor | 3 <sup>rd</sup> Floor | Total    | Notes  |
|------------------------------|-----------------------|-----------------------|----------|--|
| Capital investment           | 8,000                 | 8,000                 | 16,000   | DAIKIN equivalent split<br>system with 36,000 BTU<br>capacities.   |
| Operating cost per<br>year   | 681.12                | 681.12                | 1362     | Based on 0.06 of unit cost per<br>kWh, 4.3 kW per unit, 10 hr.<br>daily usage, 132 working<br>days per year. |
| Useful life                  | 7                     | 7                     |          | Based on office furniture and equipment asset class 00.11.   |
| MARR                         | 11%                   | 11%                   |          |  |
| Annual maintenance<br>fee    | 137                   | 137                   | 275      | [14]   |
| Installation cost            | 620                   | 620                   | 1,239    | [14]   |
| Market value after 1<br>year | 3,085.56              | 3,085.56              | 6,171.12 | 1 year depreciation (0.901)  |

Table 10: AC Option 2 analysis

PW (option 2) = -16000-(1362+275)\*(P/A, 11%, 7)-1239+6171.12\*(P/F, 11%, 1) = \$ -19,400.09

AW (option 2) = \$4,116.99

# **Option 3 Analysis**:

For the sake of meeting better individual needs of temperature setting, option 3 is proposed to install 58 window mounted ACs in offices located in 2<sup>nd</sup> and 3<sup>rd</sup> floor. The capital investment seems to be cheaper, however, the operating cost seems to be higher than other options. The detailed comparison will be made in the following sections.

|                            | Second floor | Third floor | Total | Notes   |
|----------------------------|--------------|-------------|-------|---|
| Capital<br>investment      | 3,820        | 3,566       | 7,386 | Based on 30 and 28 EA window<br>ACs in second and third floor<br>respectively |
| Operating cost<br>per year | 3,038.43     | 3,038.43    | 6,077 | Based on total 17.99 kW, \$0.06<br>cost, 10 hr a day, 132 days per<br>year    |
| Useful life                | 7            | 7           |       | Based on office furniture and equipment asset class 00.11.                    |
| MARR                       | 11%          | 11%         |       |   |
| Annual<br>maintenance fee  | 870          | 870         | 1,740 | Based on 1 hr. labor  |
| Installation cost          | 1800         | 1680        | 3,480 | Based on 2 hr labor + supplies =<br>\$60 per unit. *                          |

Table 11: AC Option 3 Analysis

PW (Option 3) = -7386 - (6077+1740) (P/A, 11%, 7) - 3480 = -47,683.40

AW (Option 3) = \$10,119.15

#### **Sensitivity Analysis**

Although every effort has been made to make the above analysis reflect the actual situation, the uncertainty involves in almost every scenario. Thus, it is necessary to conduct sensitivity analysis and try to investigate the potential range of variations when input variable changes. In addition, for more clearly to identify the benefits/savings of the above options, it is needed to calculate the potential savings as result of implementing these optional initiatives. The annual saving is calculated by comparing the operating cost difference between new options and the current AC setting in East Hall as shown in the table below. The driving factors for the saving include the operating hours (time aspects) and kWhs (energy consumption aspect). From this analysis, the ways of energy saving of East Hall are shown in Table 12 although options require capital investments. And the saving values in options were used as annual saving data in sensitivity analysis for each option.

| Energy Saving                              | Current<br>(24hr) | Saving<br>(10hr) | Option<br>1 | Option<br>2 | Option 3  |
|--|-------------------|------------------|-------------|-------------|-----------|
| Operating Time (hour) per day              | 24.0              | 10.0             | 10.0        | 10.0        | 10.0      |
| Power consumption (kW) per AC unit         | 3.0               | 3.0              | 1.4         | 4.3         | 0.7       |
| Cost of Power consumption per unit per day | 4.3               | 1.8              | 0.8         | 2.6         | 0.4       |
| Total Cost of Power consumption per day    | 25.9              | 10.8             | 5.0         | 5.2         | 23.0      |
| Operating cost per year                    | 4,708.8           | 1,962.0          | 664.3       | 1,362.2     | 6,076.9   |
| Difference (Saving) per year               |                   | 2,746.8          | 3,063.5     | 2,692.6     | (2,349.1) |
|  | Saving/unit       | 457.79916        |             |             |           |
|  | Cost/unit         | 326.9994         |             |             |           |

Table 12: AC cost saving analysis for proposed options

# **Option 1 Sensitivity Analysis**

Since the option 1 has the highest PW value, it is necessary to look at how the changes factors can influence the PW value. As can be seen from the figure below, capital investment and annual saving are considered more sensitive to the PW, due to the steeper slope. The Annual expense (including electricity cost) and MARR seems not that sensitive to the PW, compared with the capital investment.



Figure 4: AC Option 1 Sensitivity Analysis

#### **Option 2 Sensitivity Analysis**

As can be seen from the figure 5 below, option 2 has the similar sensitivity results with option 1. The capital investment and annual saving are again considered more sensitive to the PW, due to the steeper slope. The annual expense (including electricity cost) and MARR seems not that sensitive to the PW, compared with the capital investment and saving. This means that the other different class/level of potential AC with different energy consumption may influence the PW more significantly.



Figure 5: AC option 2 Sensitivity Analysis

#### **Option 3 Sensitivity Analysis**

Option 3 has different sensitivity results with option 1 and 2. The annual expense and MARR are considered more sensitive to the PW, due to the steeper slope. The annual saving seems not that sensitive to the PW. This means that the input variables in the option 3 Analysis tend not to influence the PW value significantly.



Figure 6: AC Option 3 Sensitivity Analysis

# **Results**

### **Lighting: Occupancy/Vacancy Sensor**

Based on the analysis it can be summarized that Lutron- LRF2-OCR2B-P-WH – Passive Infrared sensor is the most cost efficient occupancy sensor alternative for East Hall and it is worth the investment.

### **Refrigerator**

Old refrigerator's consumes more energy. If the new refrigerators were installed by replacing the old refrigerators, it would take approximately 2 years of energy savings to offset the initial investment of new refrigerators. Therefore, it is a good investment over a long-term period.

# **Air-conditioning**

Based on the above investigation, the AC analysis is briefly summarized as shown in the table below and listed as follows:

- Option 1 is featured with lowest operating cost and should be preferred, due to the largest PW (lowest AW) value.
- Option2 has the lowest installation cost; nevertheless, it is the capital investment making the PW relatively decreased.
- Option 3 has the lowest capital investment; however, the operating cost per year is so high that makes this option unfavorable.
- \$5.4 annuity per month per room seems to justify the improvement of working environment in East Hall.
- According to the result of sensitivity, capital investment and annual saving are regarded as major factors contributing to the variations of PW value. This may require utility manager's attention when considering option 1 or 2.

| Summary                    | Option 1 | Option 2 | Option 3 |
|----------------------------|----------|----------|----------|
| Capital Investment         | 10,800   | 16,000   | 7,386    |
| Operating cost per year    | 664      | 1,362    | 6,077    |
| Annual maintenance         | 275      | 275      | 1,740    |
| Installation cost          | 2,479    | 1,239    | 3,480    |
| Useful life                | 7        | 7        | 7        |
| MARR                       | 11%      | 11%      | 11%      |
| MV                         |          | 6171.12  |          |
| PW                         | -17,702  | -19,400  | -47,683  |
| AW                         | 3,757    | 4,117    | 10,119   |
| Annuity per month          | 313      | 343      | 843      |
| Annuity per month per room | 5.4      | 5.9      | 14.5     |

Table 13: Summary of AC analysis on East Hall

# **Conclusion and Recommendations**

Working condition is generally considered as one of the important factors affecting employee's performance. Although East hall has made some improvements by installing some AC in hallway, the second and third floor still encounter the problems of insufficient AC capacity. By considering capital investment, installation cost, annual maintenance and cost saving, to install 3 new AC in both second and third floor (option 1) is identified as the most preferred way of both enhancing the AC capacity and balance the energy efficiency. The rationale for this proposition is based on the annual worth value (AW) method and sensitivity analysis addressed in Engineering Economics theory. The AC analysis result can be simplified into the following statement: "To expense \$5.4 per room per month will be very likely to meet the AC capacity requirement and improve the working condition of East Hall."

With regard to the calculation above for Refrigerator energy efficiency measure, it is obvious that after two years, the initial investment will breakeven. Therefore, replacing old, mini refrigerators with energy efficient, full-sized refrigerators could be taken into consideration.

Reducing lighting energy usage helps in controlling associated energy cost. Turning the lights on and off based on the occupancy and user adjustable time delays along with different modes such as day-light sensing so on are few of the benefits of installing occupancy/vacancy sensors. This is important not only from economic aspect but it is also a positive effort towards conserving and saving energy.

# References

- P. S. U. S. Department, "Climate Action Plan 2010," 24 May 2010. [Online]. Available: http://www.pdx.edu/sites/www.pdx.edu.sustainability/files/ClimateActionPlan%284m b%29.pdf. [Accessed 2 June 2015].
- [2] U. G. B. C. -. USGBC, "LEED," [Online]. Available: http://www.usgbc.org/leed. [Accessed 2 June 2015].
- [3] J. Diaz, "A Comparison of Sustainability-Based Labels in Building and Construction.," University of Applied Science - Department of Architecture and Civil Engineering, Giessen -Friedberg, 2010.
- [4] P. S. University, "East Hall," [Online]. Available: http://www.pdx.edu/floorplans/buildings/eh. [Accessed 2 June 2015].
- [5] W. Sullivan, Engineering Economy, 14th Edition, Upper Saddle River, NJ: Pearson Prentice Hall, 2009.
- [6] U. D. o. Transportation, "Federal Highway Administration Asset Management," 13 5 2015.
   [Online]. Available: http://www.fhwa.dot.gov/asset/pubs.cfm?thisarea=risk. [Accessed 2 6 2015].
- [7] H. C. F. a. S. Patil, "Identification and Review of Sensitivity Analysis Methods," *Risk Analysis*, vol. 22, no. No.3, pp. 553-578, 2002.
- [8] 1000Bulbs.com, "Lutron LRF2-OCR2B-P-WH 360 Deg. Wireless Occupancy/Vacancy Ceiling Sensor," [Online]. Available: https://www.1000bulbs.com/product/101152/LUT-LRF2OCR2BWH.html. [Accessed 9 June 2015].
- [9] S. Electric, "Ultrasonic Ceiling Mounted Occupancy Sensor- 360° or 180°," Schneider Electric, La Vergne, TN, 37086, 2015.
- [10 Wattstopper, "WT Ultrasonic Ceiling Sensors," [Online]. Available: www.wattstopper.com/.../PDF/cut-sheets/Sensors/WT-Ultrasonic-Ceiling-.... [Accessed 9 June 2015].
- [11 G. A. K. a. Y. A. H. Hyung Chul Kim, ""Optimal Household Refrigerator Replacement policy for Life Cycle Energy, Greenhouse Gas Emissions, and Cost"," *Energy Policy*, vol. 34, no. 15, pp. 2310-2323, 2015.
- [12 D. DiClerico, "Consumer Reports.org A mini refrigerator can max out your utility bill," 21 March 2013. [Online]. Available: http://www.consumerreports.org/cro/news/2013/03/a-mini-refrigerator-can-maxout-your-utility-bill/index.htm. [Accessed 2 June 2015].
- [13 E. Star, "Properly Sized Room Air Conditioners," EnergyStar, [Online]. Available: https://www.energystar.gov/index.cfm?c=roomac.pr\_properly\_sized. [Accessed 9 June 2015].
- [14 G. J. K. C. L. L. D. J. E. M. a. S. M. Rosenquist, "Life-Cycle Cost and Payback Period Analysis for Commercial Unitary Air Conditioners," Lawrence Berkeley National Laboratory, Berkeley, 2004.
- [15 P. S. University, "Finance And Administration: Campus Planning and Sustainability," PSU, 2010. [Online]. Available: http://www.pdx.edu/planning-sustainability/climate-action. [Accessed 2 June 2015].

# Appendix

# **Appendix A**

Table 1: Hallway – Stairs Lighting Fixture – Floor 1, Floor 2 and Floor 3

| Floor            | Quantity (Light Fixtures) | Wattage (Watts) |
|------------------|---------------------------|-----------------|
| Floor 1          | 6 - 2                     | 34 W – 13 W     |
| Stairs – Level 1 | 8                         | 13W             |
| Floor 2          | 12                        | 13 W            |
| Stairs – Level 2 | 8                         | 13 W            |
| Floor 3          | 12                        | 13 W            |
| Stairs – Level 3 | 6                         | 13 W            |

Table 2: Space Characteristics for East Hall

Space Characteristics of each hallway and stairway of East Hall:

|  | Floor 1 | Floor 2 | Floor 3 |
|--|---------|---------|---------|
|  |         |         |         |
| Hallways Space (Left Side) (Sqaure Feet) | 120     | 349     | 300     |
|  |         |         |         |
| Ceiling Height (Feet)                    | 8       | 8.4     | 8.4     |
|  |         |         |         |
| Linear length of Hallway(Feet)           | 25.00   | 72.71   | 53.57   |
|  |         |         |         |

| Hallways Space (Right Side)(Square Feet) | 300   | 326   | 300   |
|--|-------|-------|-------|
| Ceiling Height (Feet)                    | 8     | 8.4   | 8.4   |
| Linear length of Hallway(Feet)           | 53.57 | 67.92 | 53.57 |

| Hallways Space (Center) (Square feet) | 388   | 317   | 371   |
|---------------------------------------|-------|-------|-------|
| Ceiling Height (Feet)                 | 8     | 8.4   | 8.4   |
| Linear length of Hallway(Feet)        | 54.61 | 48.71 | 51.08 |

| Stairs: Space (Left Side)  | 154 | 154 | 154 |
|----------------------------|-----|-----|-----|
|                            |     |     |     |
| Windows                    | 1   | 1   | 1   |
|                            |     |     |     |
| Area                       |     |     |     |
|                            |     |     |     |
| Stairs: Space (Right Side) | 154 | 154 | 154 |
|                            |     |     |     |
| Windows                    | 1   | 1   | 1   |
|                            |     |     |     |
| Area                       |     |     |     |
|                            |     |     |     |

# For Floor 1: Floor space is different

| Left Side: V101 | 11.70 |
|-----------------|-------|
| C105            | 30.48 |

Calculation for Present worth Alternatives:

# Present Worth for Alternatives:

| MARR | 11%    |
|------|--------|
|      |        |
| Ν    | 7      |
|      |        |
| Cost | \$0.06 |
|      |        |

|               |                         |                         | Alternative 3 Cash |
|---------------|-------------------------|-------------------------|--------------------|
| End of Year   | Alternative 1 Cash Flow | Alternative 2 Cash Flow | Flow               |
| 0             | -\$1,386.25             | -\$1,841.88             | -\$2,300           |
| 1             | 306.028                 | 306.028                 | 306.028            |
| 2             | 306.028                 | 306.028                 | 306.028            |
| 3             | 306.028                 | 306.028                 | 306.028            |
| 4             | 306.028                 | 306.028                 | 306.028            |
| 5             | 306.028                 | 306.028                 | 306.028            |
| 6             | 306.028                 | 306.028                 | 306.028            |
| 7             | 306.028                 | 306.028                 | 306.028            |
| Present Worth | \$55.81                 | -\$399.82               | -\$857.94          |

# Sensitivity Analysis Calculations:

# [I] Changes in MARR

|      | MARR | PW        |
|------|------|-----------|
| -90% | 1%   | \$664.72  |
| -80% | 2%   | \$579.22  |
| -70% | 3%   | \$499.02  |
| -60% | 4%   | \$423.70  |
| -50% | 6%   | \$352.90  |
| -40% | 7%   | \$286.27  |
| -30% | 8%   | \$223.52  |
| -20% | 9%   | \$164.37  |
| -10% | 10%  | \$108.54  |
| 0%   | 11%  | \$55.81   |
| 10%  | 12%  | \$5.97    |
| 20%  | 13%  | -\$41.19  |
| 30%  | 14%  | -\$85.85  |
| 40%  | 15%  | -\$128.18 |
| 50%  | 17%  | -\$168.32 |
| 60%  | 18%  | -\$206.44 |
| 70%  | 19%  | -\$242.64 |
| 80%  | 20%  | -\$277.07 |
| 90%  | 21%  | -\$309.82 |

[II] Changes in Capital Investment

|      | Capital Investment | PW          |
|------|--------------------|-------------|
| -90% | -\$138.63          | \$1,303.44  |
| -80% | -\$277.25          | \$1,164.81  |
| -70% | -\$415.88          | \$1,026.19  |
| -60% | -\$554.50          | \$887.56    |
| -50% | -\$693.13          | \$748.94    |
| -40% | -\$831.75          | \$610.31    |
| -30% | -\$970.38          | \$471.69    |
| -20% | -\$1,109.00        | \$333.06    |
| -10% | -\$1,247.63        | \$194.44    |
| 0%   | -\$1,386.25        | \$55.81     |
| 10%  | -\$1,524.88        | -\$82.81    |
| 20%  | -\$1,663.50        | -\$221.44   |
| 30%  | -\$1,802.13        | -\$360.06   |
| 40%  | -\$1,940.75        | -\$498.69   |
| 50%  | -\$2,079.38        | -\$637.31   |
| 60%  | -\$2,218.00        | -\$775.94   |
| 70%  | -\$2,356.63        | -\$914.56   |
| 80%  | -\$2,495.25        | -\$1,053.19 |
| 90%  | -\$2,633.88        | -\$1,191.81 |

|      | Annual Savings | PW          |
|------|----------------|-------------|
| -90% | \$30.60        | -\$1,242.04 |
| -80% | \$61.21        | -\$1,097.84 |
| -70% | \$91.81        | -\$953.63   |
| -60% | \$122.41       | -\$809.42   |
| -50% | \$153.01       | -\$665.22   |
| -40% | \$183.62       | -\$521.01   |
| -30% | \$214.22       | -\$376.80   |
| -20% | \$244.82       | -\$232.60   |
| -10% | \$275.43       | -\$88.39    |
| 0%   | \$306.03       | \$55.82     |
| 10%  | \$336.63       | \$200.02    |
| 20%  | \$367.23       | \$344.23    |
| 30%  | \$397.84       | \$488.44    |
| 40%  | \$428.44       | \$632.64    |
| 50%  | \$459.04       | \$776.85    |
| 60%  | \$489.65       | \$921.06    |
| 70%  | \$520.25       | \$1,065.27  |
| 80%  | \$550.85       | \$1,209.47  |
| 90%  | \$581.45       | \$1,353.68  |

[III] Changes in cost of electricity (Annual Savings)

# Appendix B

| Average capacity      | 4.4    | Cubit feet |
|-----------------------|--------|------------|
| Average wattage for a |        |            |
| mini refrigerator     | 0.45   | KWh        |
| electricity cost in   |        |            |
| Portland              | \$0.06 | KWh        |

# Appendix C

East Hall AC analysis Excel spreadsheet

| Option 1: Install 3 additional Air Conditioners in both second and third floor |              |             |         |
|--|--------------|-------------|---------|
|  | Second floor | Third floor | Total   |
| Square Footage   | 6,257        | 6,379       | 12,636  |
| Mininum cooling capacity required (BTU/hr)                                     | 112,626      | 114,822     | 227,448 |
| Current Air Conditioning (3 Air Conditioning)(BTU/hr)                          | 54,000       | 54,000      | 108,000 |
| Add 3 New Air conditioning (BTU/hr)  | 54,000       | 54,000      | 108,000 |
| Total cooling capacity (BTU/hr)  | 108,000      | 108,000     | 216,000 |
|  |              |             |         |
| Capital investment   | 5,400        | 5,400       | 10,800  |
| operating cost per year  | 332.1648     | 332.1648    | 664     |
| Useful life  | 7            | 7           |         |
| MARR   | 11%          | 11%         |         |
| Annual maintenance fee   | 137          | 137         | 275     |
| Installation cost  | 1,239        | 1,239       | 2,479   |
| PW (Option 1) = -10800 - (664+275) (P/A, 11%, 7) - 2478.87                     | -17,701.56   |             |         |
| AW (Option 1) =  | \$3,756.54   |             |         |

# Supplemental information/calculation for option 1:

| DAIKIN cooling capacity (BTU/Hr) per unit                                | 18,000   |
|--|----------|
| Square footage (maxmum) for 18,000 BTU                                   | 1,000    |
| Unit price for DAIKIN (cooling + fan + remote control)                   | 1,800    |
| Indoor + outdoor power (kW)  | 1.398    |
| Operating hours per day  | 10       |
| Operating month (From May to Octobor)                                    | 6        |
| Total energy consumed per day (kWh)                                      | 13.98    |
| Total energy consumed per month (22 days)(kWh)                           | 307.56   |
| unit cost per kWh  | 0.06     |
| Total energy cost per month  | 18.4536  |
| Total energy cost for 6 month (1 year usage) per AC                      | 110.7216 |
| Total energy cost for 6 month (1 year usage) for 3 Acs                   | 332.1648 |
| Annual maintenance cost for 3-tons through 24-tons AC                    | 274.97   |
| Annual installation cost for AC with range: > 65,000 and < 135,000 Btu/h | 2478.87  |

| Indoor unit power consumption (kW)=   |                            | 0.058                          |  |  |
|---------------------------------------|----------------------------|--------------------------------|--|--|
| Outdoor unit power comsumption (kW) = |                            | 1.34                           |  |  |
| Total power consumption per unit =    |                            | 1.398                          |  |  |
| Unit price =                          | <b>\$1,588.50</b> + \$198. | \$1,588.50 + \$198.25 shipping |  |  |

| Average inflation rate (from 2001 to 2014) = | 2.30%  |
|--|--------|
| Maintenance cost in 2001 =                   | 200.00 |
| Maintenance cost in 2015 =                   | 274.97 |

| Average inflation rate (from 2001 to 2014) = | 2.30%    |
|--|----------|
| Installation cost in 2001 =                  | 1,803.00 |
| Installtion cost in 2015 =                   | 2,478.87 |

| Option 2: Upgrade the AC (two 36,000 BTU AC) + sell two old ACs for both second |              |             |         |
|---|--------------|-------------|---------|
|   |              |             |         |
| Daikin - Initial investment (\$4,000/unit)                                      | Second floor | Third floor | Total   |
| Square Footage  | 6,257        | 6,379       | 12,636  |
| Mininum cooling capacity required (BTU/hr)                                      | 90,101       | 91,858      | 181,958 |
| Current Air Conditioning (3 Air Conditioning)(BTU/hr)                           | 54,000       | 54,000      | 108,000 |
| Replace 2 New Air conditioning (BTU/hr) - 36,000BTU*2                           | 72,000       | 72,000      | 144,000 |
| Total cooling capacity (BTU/hr)   | 90,000       | 90,000      | 180,000 |
|   |              |             |         |
| Capital investment  | 8,000        | 8,000       | 16,000  |
| operating cost per year   | 681.12       | 681.12      | 1,362   |
| Useful life   | 7            | 7           |         |
| MARR  | 11%          | 11%         |         |
| Annual maintenance fee  | 137          | 137         | 275     |
| Installation cost   | 620          | 620         | 1,239   |
| Market value after 1 year   | 3085.56      | 3085.56     | 6171.12 |
|   |              |             |         |
| PW (Option 2) = -16000-(1362+275)*(P/A, 11%, 7)-1239+3085*(P/F, 11%, 1)*2       | -19,400.09   |             |         |
| AW (Option 2)=  | \$4,116.99   |             |         |

# Supplemental information/calculation for option 2:

| DAIKIN cooling capacity (BTU/Hr) per unit                                | 36,000   |
|--|----------|
| Square footage for 36,000 BTU  | 2,500    |
| Unit price for DAIKIN (cooling + fan + remote control)                   | 4,000    |
| Indoor + outdoor power (kW)  | 4.3      |
| Operating hours per day  | 10       |
| Operating month (From May to Octobor)                                    | 6        |
| Total energy consumed per day (kWh)                                      | 43       |
| Total energy consumed per month (22 days)(kWh)                           | 946      |
| unit cost per kWh  | 0.06     |
| Total energy cost per month  | 56.76    |
| Total energy cost for 6 month (1 year usage) per AC                      | 340.56   |
| Total energy cost for 6 month (1 year usage) for 2 ACs (36000*2)         | 681.12   |
| Annual maintenance cost for 3-tons through 24-tons AC                    | 274.97   |
| Annual installation cost for AC with range: > 65,000 and < 135,000 Btu/h | 2478.87  |
| Installation saving (using original AC pipeline)(50%)(assumption)        | 1239.435 |

| Indoor + outc  | 4.3                            |  |  |  |
|----------------|--------------------------------|--|--|--|
|                |                                |  |  |  |
| Total power of | 4.3                            |  |  |  |
| Unit price =   | \$3,885.99 + \$142.25 shipping |  |  |  |

| Option 3: Install Window mounted AC in sence and third floor |              |             |       |
|--|--------------|-------------|-------|
|  | Second floor | Third floor | Total |
| Capital investment   | 3,820        | 3,566       | 7,386 |
| operating cost per year                                      | 3,038.43     | 3,038.43    | 6,077 |
| Useful life  | 7            | 7           |       |
| MARR   | 11%          | 11%         |       |
| Annual maintenance fee                                       | 870          | 870         | 1,740 |
| Installation cost  | 1800         | 1680        | 3,480 |
|  |              |             |       |
|  |              |             |       |
|  |              |             |       |
| PW (Option 3) = -7386 -(6077+1740) (P/A, 11%, 7) - 3480 =    | -47,683.40   |             |       |
| AW (Option 3) =  | \$10,119.15  |             |       |

# Supplemental information/calculation for option 3:

| Total window mounted AC needed                       | 30        |
|--|-----------|
| Total price for 30 window mounted AC                 | 3,820     |
| Total kW consumed by all Window mounted AC in        | 38.364    |
| Operating hours per day                              | 10        |
| Operating month (From May to Octobor)                | 6         |
| Total energy consumed per day (kWh)                  | 383.64    |
| Total energy consumed per month (22 days)(kWh)       | 8440.08   |
| unit cost per kWh                                    | 0.06      |
| Total energy cost per month                          | 506.4048  |
| Total energy cost for 6 month (1 year usage) for all | 3038.4288 |
| Annual maintenance cost per AC (0.5 hr labor) =      | 15        |
| Annual installation cost per AC (2 hr labor)=        | 60        |

| Second floor | Count | Price | Initial Cost | volt | amp | watt  | kW     | Total kW |
|--------------|-------|-------|--------------|------|-----|-------|--------|----------|
| 5000 BTU     | 17    | 119   | 2023         | 115  | 4.8 | 552   | 0.552  | 9.384    |
| 6000 BTU     | 10    | 115   | 1150         | 115  | 5.2 | 598   | 0.598  | 5.98     |
| 8000 BTU     | 2     | 209   | 418          | 115  | 6.5 | 747.5 | 0.7475 | 1.495    |
| 12000 BTU    | 1     | 229   | 229          | 115  | 9.8 | 1127  | 1.127  | 1.127    |
|              | 30    |       | 3820         |      |     |       | Total  | 17.986   |

| Third floor | Count | Price | Initial Cost | volt | amp | watt  | kW     | Total kW |
|-------------|-------|-------|--------------|------|-----|-------|--------|----------|
| 5000 BTU    | 11    | 119   | 2023         | 115  | 4.8 | 552   | 0.552  | 9.384    |
| 6000 BTU    | 14    | 115   | 1610         | 115  | 5.2 | 598   | 0.598  | 8.372    |
| 8000 BTU    | 2     | 209   | 418          | 115  | 6.5 | 747.5 | 0.7475 | 1.495    |
| 12000 BTU   | 1     | 229   | 229          | 115  | 9.8 | 1127  | 1.127  | 1.127    |
|             | 28    |       | 4280         |      |     |       | Total  | 20.378   |